

Notification of Reportable Storm Overflow Discharge

In accordance with the Environment Agency discharge consent schedules for **Reportable Storm Discharges**, I am writing to confirm that there was a Storm Discharge of sewage effluent, but within Compliance of the site consent, from the following site. The details of the occurrence are:

Site Name and County	Discharge Point Map Reference	Time and Duration of Storm Discharge
Budds Farm Havant CEO (Consent: A751/H/97, schedule 04) SE5	SU 7054 0510	Three discharges of settled screened storm sewage (from storm tanks) occurred on 21/03/10 between 11:54 and 21:59 The duration was 03 hours 33 minutes. The discharges were due to rainfall. The site was operating correctly.

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours

Mandar Marathe 07912393896
Kalaivani kalaivani3.r@tcs.com

Confidential Information

Privileged information may be contained in this fax and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this fax by mistake, please telephone the sender

Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX
Registered in England No. 2366670