

Notification of Reportable Storm Overflow Discharge

In accordance with the Environment Agency discharge consent schedules for **Reportable Storm Discharges**, I am writing to confirm that there was a Storm Discharge of sewage effluent, but within Compliance of the site consent, from the following site. The details of the occurrence are:

Site Name and County	Discharge Point Map Reference	Time and Duration of Storm Discharge
Budds Farm Havant CEO (Consent: A751/H/97, schedule 04) SE5	SU 7054 0510	6 discharges of settled screened storm sewage (from the storm tanks) occurred from this site between 23/12/09 22:35 and 02/01/10 13:18. The total spill duration was 157 hours 22 minutes. This discharge was due to rainfall in the area. The site was operating correctly.

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours:

Sarah Ford (01273) 663 571

Confidential Information

Privileged information may be contained in this fax and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this fax by mistake, please telephone the sender
Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX Registered in England No. 2366670