

Notification of Reportable Storm Overflow Discharge

In accordance with the Environment Agency discharge consent schedules for **Reportable Storm Discharges**, I am writing to confirm that there was a Storm Discharge of sewage effluent, but within Compliance of the site consent, from the following site. The details of the occurrence are:

Site Name and County	Discharge Point Map Reference	Time and Duration of Storm Discharge
Budds Farm Havant CEO (Consent no. A752/H/97, schedule 01) SE7	SU 7072 0570	A discharge of screened storm sewage (from inlet) occurred from this site on 30/12/09 between 01:18 and 01:23. The total duration was 5 minutes. These discharges were due to rainfall. The site was operating correctly.

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours:

Sarah Ford (01273) 663 571

Confidential Information

Privileged information may be contained in this fax and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this fax by mistake, please telephone the sender

Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX Registered in England No. 2366670