

Notification of Reportable Storm Overflow Discharge

In accordance with the Environment Agency discharge consent schedules for **Reportable Storm Discharges**, I am writing to confirm that there was a Storm Discharge of sewage effluent, but within Compliance of the site consent, from the following site. The details of the occurrence are:

Site Name and County	Discharge Point Map Reference	Time and Duration of Storm Discharge
Budds Farm Havant CEO (Consent: A751/H/97, schedule 04) SE5	SU 7054 0510	Further to the notification issued on 22/01/10, SWS can confirm the following details: Four discharges of settled screened storm sewage (from the storm tanks) occurred from this site between 20/01/10 08:57 and 26/01/10 02:31. The duration was 125 hours 22 minutes. This discharge was due to rainfall. The site was operating correctly.

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours:

Sarah Ford (01273) 663 571

Confidential Information

Privileged information may be contained in this fax and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this fax by mistake, please telephone the sender

Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX Registered in England No. 2366670