

Notification of Registered Overflow Discharge Signal

I am writing to confirm that there was a discharge signal registered from the following site. The details of the occurrence are:

Site Name and County	Discharge Point Map Reference	Time and Duration of Storm Discharge
Budds Farm Havant CEO (Consent: A751/H/97, schedule 04) SE5	SU 7054 0510	A discharge of settled screened storm sewage (from the storm tanks) occurred from this site between 23/03/10 20:25 and 24/03/10 02:25. The duration was 6 hours . SWS will confirm full details once established

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours:

Mandar Marathe 07912393896
Kalaivani kalaivani3.r@tcs.com

Confidential Information

Privileged information may be contained in this fax and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this fax by mistake, please telephone the sender

Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX Registered in England No. 2366670