

### ***Notification of Reportable Storm Overflow Discharge***

In accordance with the Environment Agency discharge consent schedules for **Reportable Storm Discharges**, I am writing to confirm that there was a Storm Discharge of sewage effluent, but within Compliance of the site consent, from the following site. The details of the occurrence are:

<b>Site Name and County</b>	<b>Discharge Point Map Reference</b>	<b>Time and Duration of Storm Discharge</b>
Budds Farm Havant CEO (Consent no. A752/H/97, schedule 01) SE7	SU 7072 0570	2 discharges of screened storm sewage (from inlet) occurred from this site on 22/02/10 06:12 and 06:42.  The total duration was 24 minutes.  These discharges were due to rainfall.  The site was operating correctly.

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours:

Mandar Marathe 07912393896  
Kalaivani kalaivani3.r@tcs.com

**Confidential Information**

Privileged information may be contained in this fax and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this fax by mistake, please telephone the sender  
Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX Registered in England No. 2366670