

### *Notification of Registered Overflow Discharge Signal*

I am writing to confirm that there was a discharge signal registered from the following site. The details of the occurrence are:

<b>Site Name and County</b>	<b>Discharge Point Map Reference</b>	<b>Time and Duration of Storm Discharge</b>
Budds Farm Havant SST (Consent: A751/H/97, schedule 04) SE5	SU 7080 0557	A discharge signal was recorded of settled screened storm sewage (from storm tanks) on 13/05/2010 between 12:37 and 13:52  The total recorded duration was 01 hour 14 minutes.  <b>SWS will confirm full details once established</b>

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours

Shailendra Patel 01903-27-2929  
Vasuki.T@southernwater.co.uk

**Confidential Information**

Privileged information may be contained in this fax and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this fax by mistake, please telephone the sender

Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX  
Registered in England No. 2366670