

Notification of Reportable Storm Overflow Discharge

In accordance with the Environment Agency discharge consent schedules for **Reportable Storm Discharges**, I am writing to confirm that there was a Storm Discharge of sewage effluent, but within Compliance of the site consent, from the following site. The details of the occurrence are:

Site Name and County	Discharge Point Map Reference	Time and Duration of Storm Discharge
Budds Farm Havant SST (Consent: A751/H/97, schedule 04) SE5	SU 7054 0510	Further to the notification issued on 23/02/10, SWS can confirm: A discharge signal occurred from settled screened storm sewage (from storm tanks) between 21/02/10 05:50 and 03/03/10 01:15. The total spill duration was 235 hours 24 minutes. This discharge was due to rainfall in the area. The site was operating correctly.

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours

Mandar Marathe 07912393896
Kalaivani kalaivani3.r@tcs.com

Confidential Information

Privileged information may be contained in this fax and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this fax by mistake, please telephone the sender

Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX
Registered in England No. 2366670