

Notification of Registered Overflow Discharge Signal

I am writing to confirm that there was a discharge signal registered from the following site. The details of the occurrence are:

Site Name and County	Discharge Point Map Reference	Time and Duration of Storm Discharge
Budds Farm Havant SST (Consent: A751/H/97, schedule 04) SE5	SU 7054 0510	2 discharges signal was recorded of settled screened storm sewage (from storm tanks) between 25/01/10 13:37 and 29/03/10 01:01 The total recorded duration was 36 hours 45 minutes. SWS will confirm full details once established

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours

Shailendra Patel 01273-66-3172
Vasuki.T@southernwater.co.uk

Confidential Information

Privileged information may be contained in this fax and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this fax by mistake, please telephone the sender

Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX
Registered in England No. 2366670