

Notification of Discharge

I am writing to confirm that there was a discharge of sewage effluent from the following site. The details of the occurrence are:

Site Name and County	Discharge Point Map Reference	Time and Duration of Storm Discharge
Court Lane, Cosham CEO EA Consent Ref: A657/H/87	SU 6622 0446	Further to the notification issued on 25/01/10, SWS can confirm the following details: A discharge occurred from this site on 22/01/10 between 10:46 and 14:03. The duration was 3 hours 16 minutes. The discharge was due to rainfall and pump failure. The pumps were repaired and the site was returned to normal operation prior to cessation of the storm event

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours:

Sarah Ford (01273) 663571

Confidential Information

Privileged information may be contained in this notification and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this notification by mistake, please telephone the sender
Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX Registered in England No. 2366670