



To: Eamon St. Lawrence (Environment Agency) Simon Moody (Environment Agency) Langstone Harbour Master's Office	From: Southern Water
Company: As above	Date: 16 January 08
Fax Number: 01962 841573, 02392 467144	Page 1 of 1

Notification of Reportable Storm Overflow Discharge

In accordance with the Environment Agency discharge consent schedules for **Reportable Storm Discharges**, I am writing to confirm that there was a Storm Discharge of sewage effluent, but within Compliance of the site consent, from the following site. The details of the occurrence are:

Site Name and County	Discharge Point Map Reference	Time and Duration of Storm Discharge
Budds Farm Havant CEO (Consent: A752/H/97)	SU 7072 0570	<p>Further to the notification issued 14/01/08, SWS can now confirm:</p> <p>3 discharges occurred from pumping station three between 11/01/08 at 0952 until 15/01/08 at 1535. The total duration was 101 hours 28 minutes.</p> <p>A discharge started from the storm tanks on 11/01/08 at 1014. The discharge is still ongoing at the time this notification was issued.</p> <p>SWS will confirm full details of the ongoing discharge once obtained.</p> <p>The discharge began due to the shaft snapping in a DWF pump. Since then, the same has happened to a second DWF pump. The site is passing forward the full flow to treatment.</p> <p>Heavy rain was the main cause of the discharges.</p> <p>Contractors are currently on site repairing the pumps.</p>

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours:
Sarah Ford (01273) 663 571

Confidential Information

Privileged information may be contained in this notification and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this notification by mistake, please telephone the sender
Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX Registered in England No. 2366670