



To: Eamon St. Lawrence (Environment Agency) Simon Moody (Environment Agency) Langstone Harbour Master's Office	From: Southern Water
Company: As above	Date: 18 January 08
Fax Number: 01962 841573, 02392 467144	Page 1 of 1

Notification of Reportable Storm Overflow Discharge

In accordance with the Environment Agency discharge consent schedules for **Reportable Storm Discharges**, I am writing to confirm that there was a Storm Discharge of sewage effluent, but within Compliance of the site consent, from the following site. The details of the occurrence are:

Site Name and County	Discharge Point Map Reference	Time and Duration of Storm Discharge
Budds Farm Havant CEO (Consent: A752/H/97)	SU 7072 0570	<p>Further to the notifications issued on 14th and 16th January 08, SWS would like to clarify:</p> <p>2 Formula A discharges occurred on 11/01/08 between 1039 and 1144. The duration was 50 minutes.</p> <p>9 discharges occurred from pumping station three between 11/01/08 0952 and 16/01/08 0039. The total duration was 109 hours 18 minutes.</p> <p>A discharge occurred from the storm tanks between 11/01/08 1014 and 18/01/08 0244. The duration was 160 hours 30 minutes.</p> <p>It was previously notified that the discharge began due to a DWF pump fault, however on further investigation SWS can now confirm:</p> <p>The discharges were instigated by the failure of the washwater system. This was quickly repaired on the same morning.</p> <p>After this event, heavy rainfall was the cause of the discharges.</p> <p>In light of the issue of this notification, please disregard the previous notifications issued on 14th and 16th January.</p>

If you have any queries regarding the above, please do not hesitate to contact:

Sarah Ford (01273) 663 571

Confidential Information: Privileged information may be contained in this notification and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this notification by mistake, please telephone the sender

Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX
Registered in England No. 2366670