



<b>To:</b> Eamon St. Lawrence (Environment Agency) Simon Moody (Environment Agency) Langstone Harbour Master's Office	<b>From:</b> Southern Water
<b>Company:</b> As above	<b>Date:</b> 12 March 08
	<b>Page 1 of 1</b>

***Notification of Reportable Storm Overflow Discharge***

In accordance with the Environment Agency discharge consent schedules for **Reportable Storm Discharges**, I am writing to confirm that there was a Storm Discharge of sewage effluent, but within Compliance of the site consent, from the following site. The details of the occurrence are:

<b>Site Name and County</b>	<b>Discharge Point Map Reference</b>	<b>Time and Duration of Storm Discharge</b>
Budds Farm Havant CEO (Consent: A752/H/97)	SU 7072 0570	A discharge occurred from the storm tanks on 11/03/08 between 1120 and 1920. The duration was 8 hours.  The discharge was due to rainfall in the area.  The site was operating correctly.

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours:

Sarah Ford (01273) 663 571

**Confidential Information**

Privileged information may be contained in this notification and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this notification by mistake, please telephone the sender

Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX  
Registered in England No. 2366670