



<b>To:</b> Eamon St. Lawrence (Environment Agency) Simon Moody (Environment Agency) Langstone Harbour Master's Office	<b>From:</b> Southern Water
<b>Company:</b> As above	<b>Date:</b> 16 January 08
<b>Fax Number:</b> 01962 841573, 02392 467144	<b>Page 1 of 1</b>

### *Notification of Reportable Storm Overflow Discharge*

In accordance with the Environment Agency discharge consent schedules for **Reportable Storm Discharges**, I am writing to confirm that there was a Storm Discharge of sewage effluent, but within Compliance of the site consent, from the following site. The details of the occurrence are:

Site Name and County	Discharge Point Map Reference	Time and Duration of Storm Discharge
Budds Farm Havant CEO (Consent: A752/H/97)	SU 7072 0570	6 discharges occurred from pumping station three between 15/01/08 at 1544 and 16/01/08 at 0038. The total duration was 7 hours 50 minutes.  Two DWF pumps are out of service due to the shafts snapping. Contractors are currently on site repairing the pumps.  Heavy rain was the main cause of the discharges.  The site is passing forward the full flow to treatment.

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours:

Sarah Ford (01273) 663 571

#### **Confidential Information**

Privileged information may be contained in this notification and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this notification by mistake, please telephone the sender  
Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX  
Registered in England No. 2366670