



<b>To:</b> Langstone Harbour Master's Office Shellfish Local Council (LFA) Local EA	<b>From:</b> Southern Water
<b>Company:</b> As above	<b>Date:</b> 11 March 08
<b>Fax Number:</b> 02392 467144, 02392 446 659	<b>Page 1 of 1</b>

### *Notification of Emergency Overflow Discharge*

In accordance with the Environment Agency discharge consent schedules for **Emergency Discharges**, I am writing to confirm that there was a Emergency Discharge of sewage effluent, but within Compliance of the site consent, from the following site. The details of the occurrence are:

<b>Site Name and County</b>	<b>Discharge Point Map Reference</b>	<b>Time and Duration of Storm Discharge</b>
Court Lane, Cosham CEO EA Consent Ref: A657/H/87	SU 6622 0446	5 discharges occurred on 10/03/08 between 0737 and 1228. The total duration was 1 hour 25 minutes.  The discharges were due to rainfall and pump failures. The pumps overheated but were restored later in the morning.  The site is now operating correctly.

If you have any queries regarding the above, please do not hesitate to contact the following people during working hours:

Sarah Ford (01273) 663 571

#### **Confidential Information**

Privileged information may be contained in this notification and is intended only for the use of the addressee. If you are not the addressee, please do not copy or deliver this to anyone else. If you receive this notificatino by mistake, please telephone the sender  
Southern Water Services Limited Registered Office: Southern House, Yeoman Road, Worthing BN13 3NX Registered in England No. 2366670